



APPALACHIAN MOUNTAIN ADVOCATES

Virginia
415 Seventh Street NE
Charlottesville, VA 22902
(434) 529-6787

West Virginia
Post Office Box 507
Lewisburg, WV 24901
(304) 645-9006

www.appalmad.org

Great Horned Owl © Estate of Roger Tory Peterson. All rights reserved.

11 December 2015

William Roller, President
Swanson Plating Corporation, Inc.
2608 Smithtown Road
Morgantown, West Virginia 26508

By Certified Mail — Return Receipt Requested

Re: **Sixty-Day Notice of Intent to File Citizen Suit Under Clean Water Act Section 505(a)(1) for Violation of Terms and Conditions of West Virginia NPDES Permit No. WV0070076**

Dear Mr. Roller:

The Sierra Club, in accordance with Section 505 of the Clean Water Act (the "Act" or the "CWA"), 33 U.S.C. § 1365, and 40 C.F.R. Part 135, hereby notifies you that the Swanson Plating Corporation ("Swanson") has violated, and continues to violate, "an effluent standard or limitation" under Section 505(a)(1)(A) of the Act, 33 U.S.C. § 1365(a)(1)(A), by failing to comply with the terms of West Virginia / National Pollution Discharge Elimination System ("WV/NPDES") Permit No. WV0070076. Furthermore, Swanson is in ongoing and continuous violation of Section 301 of the Act, 33 U.S.C. § 1311, as a result of its discharges into West Virginia's waters in excess of applicable effluent limitations. If within sixty days of the postmark of this letter Swanson does not bring itself into full compliance with the Act, we intend to file a citizens' suit seeking civil penalties for ongoing and continuing violations and for an injunction compelling it to come into compliance with the Act.

Swanson holds WV/NPDES Permit No. WV0070076 (the "Permit"), which regulates discharges from Swanson's facility in Monongalia County, West Virginia (the "Facility"). The Permit requires that Swanson monitor the volume and/or concentration of pollutants in the effluent it discharges into Toms Run, a tributary of the Monongahela River and a water of the United States. The Permit also sets limits on the volume and/or concentration of pollutants Swanson may discharge. Those limits are known as effluent limitations, and the violation of an effluent limitation is actionable under Section 505(a)(1) of the Act.

The Permit requires that Swanson submit discharge monitoring reports (“DMRs”) to the West Virginia Department of Environmental Protection (the “WVDEP”)—the agency charged with administering the WV/NPDES program. The DMRs Swanson provided to the WVDEP for the period of March 30, 2009 through November 19, 2015, however, reveal at least 304 violations of the numeric effluent limitations and reporting requirements governing Outlet 009 of the Permit for the parameters Total Residual Chlorine, Total Ammonia Nitrogen, Through-Plant or In-Conduit Flow, Biochemical Oxygen Demand, pH, Dissolved Oxygen, Total Suspended Solids, and Fecal Coliform. Swanson’s DMRs also reveal at least four (4) violations of the numeric effluent limitations governing Outlet 005 of the permit for the parameters of Temperature and pH.

Each discharge amount that exceeds permit limits is an unlawful and unpermitted discharge and, therefore, is not shielded from liability under Section 402(k) of the Clean Water Act. Swartz v. Beach, 229 F. Supp. 2d 1239, 1269 (D. Wyo. 2001); U.S. E.P.A., Revised Policy Statement on Scope of Discharge Authorization and Shield Associated with NPDES Permits at 2, n.1 (April 11, 1995) (explaining that, in a NPDES permit, “authorization is only provided to discharge such pollutants within the limits and subject to the conditions set forth in the permit” (emphasis added)). When assessing civil penalties, the federal courts consider a violation of an average monthly effluent limitation to be a violation of the limit for each and every day of the month that the violation occurred. See, e.g., Chesapeake Bay Found., Inc. v. Gwaltney of Smithfield, Ltd., 791 F.2d 304, 313–15 (4th Cir. 1986), vac’d on other grounds, 484 U.S. 49 (1987). Under that rule, Swanson has accrued 4,846 days of violations of the numeric effluent limitations and reporting requirements in the Permit.

In addition to numeric effluent limitations, the Permit also requires that all discharges be “of such quality so as not to cause violation of applicable water quality standards.” This includes the narrative water quality standards encoded in W. Va. Code R. § 47-2-3 and prohibiting the presence of waste in state waters that causes or materially contributes to, in relevant part: (1) “odors in the vicinity of the waters,” W. Va. Code R. § 47-2-3.2.c; (2) “odor that would adversely affect the designated uses of the affected waters,” W. Va. Code R. § 47-2-3.2.d; or (3) “[a]ny other condition . . . which adversely alters the integrity of the waters of the State,” W. Va. Code R. § 47-2-3.2.i. The Rules further disallow any “significant adverse impact to the chemical, physical, hydrologic, or biological components of aquatic ecosystems.” W. Va. Code R. § 47-2-3.2.i. Citizens may enforce these narrative water quality standards as effluent limitations where, as here, they are incorporated as a condition of an NPDES permit. See Ohio Valley Envtl. Coalition v. Fola Coal Co., 82 F. Supp. 3d 673, 678 (S.D. W. Va. 2015); Ohio Valley Envtl. Coalition, Inc. v. Elk Run Coal Co., 24 F. Supp. 3d 532 (S.D. W. Va. 2014); Ohio Valley Envtl. Coalition, Inc. v. Alex Energy, Inc., 12 F. Supp. 3d 844 (S.D. W. Va. 2014); Ohio Valley Envtl. Coalition, Inc. v. CONSOL of Kentucky, Inc., Civ. No. 2:13-cv-5005, 2014 WL 1761938 at *3 (S.D. W. Va. Apr. 30, 2014); Ohio Valley Envtl. Coalition, Inc. v. Fola Coal Co., LLC, Civ. No. 2:12-cv-3750, 2013 WL 6709957 at *21 (S.D. W. Va. Dec. 19, 2013); Ohio Valley Envtl. Coalition, Inc. v. Marfork Coal Co., Inc., 966 F. Supp. 2d 667, 685 (S.D. W. Va. 2013). See also, e.g., Northwest Envtl. Advocates v. City of Portland, 56 F.3d 979, 986-88 (9th


Cir. 1995); New Manchester Resort & Golf, LLC v. Douglasville Development, LLC, 734 F. Supp. 2d 1326, 1226-39 (N.D. Ga. 2010); Swartz v. Beach, 229 F. Supp. 2d 1239, 1270-72 (D. Wyo. 2002); Gill v. LDI, 19 F. Supp. 2d 1188, 1195 (W.D. Wash. 1998).

Toms Run is designated for recreational use and for use as an aquatic habitat. See W. Va. Code R. § 47-2-6.1. However, the World Health Organization warns that water can be malodorous when ammonia concentrations are as low as 1.5 mg/l. See World Health Org., “Ammonia in Drinking-Water,” Guidelines for Drinking-Water Quality (2d ed. 1996). By comparison, DMRs submitted by Swanson reveal that in one recent month, for example, the Facility discharged approximately 22,000 gallons of water per day with an average ammonia concentration of 10.10 mg/l. Depending on ambient conditions at the time,¹ such discharges may have “cause[d] or materially contribute[d] to . . . odors in the vicinity of the waters” and to “odors that would adversely affect the designated uses of” Toms Run. See W. Va. Code R. §§ 47-2-3.2.

In the absence of any indication that Swanson has made serious efforts to prevent similar violations in the future, we believe Swanson is in ongoing and continuing violation of these effluent limitations and thus subject to a citizen suit under Section 505(a)(1) of the Act. If Swanson fails to come into complete compliance with the Act and the terms of its Permit, then we intend to file a citizen suit under Section 505(a)(1) of the Act for civil penalties and injunctive relief. Be aware that this notice is sufficient to allow us to sue Swanson for any post-notice violations related to the violations described herein. See generally Public Interest Research Group of N.J. v. Hercules, Inc., 50 F.3d 1239 (3d Cir. 1995).

If Swanson has taken any steps to eradicate the underlying cause or causes of the violations identified in this letter, or if Swanson believes that anything in this letter is inaccurate, please let us know. If Swanson does not advise us of any remedial steps during the sixty-day period, we will assume no such steps have been taken and that violations are likely to continue. Additionally, we would be happy to meet with Swanson or its representatives to attempt a resolution of these issues within the sixty-day notice period.

Sincerely,



Evan D. Johns

Joseph M. Lovett

Appalachian Mountain Advocates

415 Seventh Street Northeast

Charlottesville, Virginia 22902

ejohns@appalmad.org

(304) 439 - 0303

¹ According to the WVDEP, Toms Run's 7Q10 flow is 0.0033 cubic feet per second—approximately 1,939 gallons per day.

Counsel for:

Sierra Club
85 Second Street, Second Floor
San Francisco, California 94105
(415) 977 – 5680

CC (Via Certified Mail, Return Receipt Requested):

The Honorable Randy Huffman, Secretary
West Virginia Department of Environmental Protection
601 Fifty-Seventh Street
Charleston, West Virginia 25304

The Honorable Shawn M. Garvin, Regional Administrator
United States Environmental Protection Agency Region III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029

The Honorable Gina McCarthy, Administrator
United States Environmental Protection Agency
Ariel Rios Building
1200 Pennsylvania Avenue Northwest
Washington, District of Columbia 20460

Paul Collins
2608 Smithtown Road
Morgantown, West Virginia 26508

APPENDIX A

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Chlorine, Total Residual	October 2015	Avg. Monthly	0.02	0.012	mg/l	31*
pH	October 2015	Inst. Min.	5.45	6 ⁺	S.U.	1
Chlorine, Total Residual	September 2015	Avg. Monthly	1.10	0.012	mg/l	30*
Chlorine, Total Residual	September 2015	Max. Daily	2.20	0.023	mg/l	1
Dissolved Oxygen	August 2015	Inst. Min.	4.9	6 ⁺	mg/l	1
Flow, In Conduit or Through Plant	July 2015	Max. Daily	0.0158	0.0075	mgd	1
Dissolved Oxygen	July 2015	Inst. Min.	3.6	6 ⁺	mg/l	1
Nitrogen, Ammonia Total	July 2015	Avg. Monthly	0.46653	0.19	lbs/day	31*
Nitrogen, Ammonia Total	July 2015	Max. Daily	0.46653	0.38	lbs/day	1
Nitrogen, Ammonia Total	July 2015	Avg. Monthly	3.54	3	mg/l	31*
Nitrogen, Ammonia Total	May 2015	Avg. Monthly	9.62	3	mg/l	31*
Nitrogen, Ammonia Total	May 2015	Max. Daily	9.62	6	mg/l	1
Chlorine, Total Residual	May 2015	Avg. Monthly	0.46	0.012	mg/l	31*
Chlorine, Total Residual	May 2015	Max. Daily	0.46	0.023	mg/l	1
Flow, In Conduit or Through Plant	April 2015	Max. Daily	0.022	0.0075	mgd	1
Biochemical Oxygen Demand	April 2015	Avg. Monthly	0.918	0.31	lbs/day	30*
Biochemical Oxygen Demand	April 2015	Max. Daily	0.918	0.62	lbs/day	1
Nitrogen, Ammonia Total	April 2015	Avg. Monthly	1.85337	0.19	lbs/day	30*
Nitrogen, Ammonia Total	April 2015	Max. Daily	1.85337	0.38	lbs/day	1
Nitrogen, Ammonia Total	April 2015	Avg. Monthly	10.10	3	mg/l	30*
Nitrogen, Ammonia Total	April 2015	Max. Daily	10.10	6	mg/l	1
Biochemical Oxygen Demand	February 2015	Avg. Monthly	6	5	mg/l	28*
Nitrogen, Ammonia Total	February 2015	Avg. Monthly	0.29694	0.19	lbs/day	28*
Nitrogen, Ammonia Total	February 2015	Avg. Monthly	17.80	3	mg/l	28*
Nitrogen, Ammonia Total	February 2015	Max. Daily	17.80	6	mg/l	1
Chlorine, Total Residual	February 2015	Avg. Monthly	0.02	0.012	mg/l	28*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Chlorine, Total Residual	December 2014	Avg. Monthly	0.04	0.012	mg/l	31*
Chlorine, Total Residual	December 2014	Max. Daily	0.04	0.023	mg/l	1
Chlorine, Total Residual	November 2014	Avg. Monthly	0.02	0.012	mg/l	30*
pH	October 2014	Inst. Min.	4.83	6 ⁺	S.U.	1
Nitrogen, Ammonia Total	October 2014	Avg. Monthly	4.3	3	mg/l	31*
pH	September 2014	Inst. Min.	4.24	6 ⁺	S.U.	1
Chlorine, Total Residual	September 2014	Avg. Monthly	0.02	0.012	mg/l	30*
Dissolved Oxygen	August 2014	Inst. Min.	5.6	6 ⁺	mg/l	1
Chlorine, Total Residual	August 2014	Avg. Monthly	0.14	0.012	mg/l	31*
Chlorine, Total Residual	August 2014	Max. Daily	0.14	0.023	mg/l	1
Nitrogen, Ammonia Total	July 2014	Avg. Monthly	4.0	3	mg/l	31*
Chlorine, Total Residual	June 2014	Avg. Monthly	0.02	0.012	mg/l	30*
Biochemical Oxygen Demand	May 2014	Avg. Monthly	18	5	mg/l	31*
Biochemical Oxygen Demand	May 2014	Max. Daily	18	10	mg/l	1
pH	May 2014	Inst. Min.	4.24	6 ⁺	S.U.	1
Nitrogen, Ammonia Total	May 2014	Avg. Monthly	11.6	3	mg/l	31*
Nitrogen, Ammonia Total	May 2014	Max. Daily	11.6	6	mg/l	1
Chlorine, Total Residual	July 2014	Avg. Monthly	0.03	0.012	mg/l	31*
Chlorine, Total Residual	July 2014	Max. Daily	0.03	0.023	mg/l	1
Chlorine, Total Residual	April 2014	Avg. Monthly	0.63	0.012	mg/l	30*
Chlorine, Total Residual	April 2014	Max. Daily	0.63	0.023	mg/l	1
Biochemical Oxygen Demand	March 2014	Avg. Monthly	6.0	5	mg/l	31*
pH	March 2014	Inst. Min.	5.63	6 ⁺	S.U.	1
Nitrogen, Ammonia Total	March 2014	Avg. Monthly	6.47	3	mg/l	31*
Nitrogen, Ammonia Total	March 2014	Max. Daily	6.47	6	mg/l	1
Nitrogen, Ammonia Total	February 2014	Avg. Monthly	5.75	3	mg/l	28*
Chlorine, Total Residual	February 2014	Avg. Monthly	0.02	0.012	mg/l	28*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Nitrogen, Ammonia Total	January 2014	Avg. Monthly	0.2789	0.19	lbs/day	31*
Nitrogen, Ammonia Total	January 2014	Avg. Monthly	15.2	3	mg/l	31*
Nitrogen, Ammonia Total	January 2014	Max. Daily	15.2	6	mg/l	1
pH	December 2013	Inst. Min.	5.69	6 [†]	S.U.	1
Nitrogen, Ammonia Total	December 2013	Avg. Monthly	15.2	3	mg/l	31*
Nitrogen, Ammonia Total	December 2013	Max. Daily	15.2	6	mg/l	1
Chlorine, Total Residual	December 2013	Avg. Monthly	0.02	0.012	mg/l	31*
Chlorine, Total Residual	November 2013	Avg. Monthly	0.02	0.012	mg/l	30*
Chlorine, Total Residual	October 2013	Avg. Monthly	0.05	0.012	mg/l	31*
Chlorine, Total Residual	October 2013	Max. Daily	0.05	0.023	mg/l	1
pH	September 2013	Inst. Min.	5.78	6 [†]	S.U.	1
Dissolved Oxygen	September 2013	Inst. Min.	5.82	6 [†]	mg/l	1
Chlorine, Total Residual	August 2013	Avg. Monthly	0.06	0.012	mg/l	31*
Chlorine, Total Residual	August 2013	Max. Daily	0.06	0.023	mg/l	1
pH	July 2013	Inst. Min.	5.78	6 [†]	S.U.	1
Dissolved Oxygen	July 2013	Inst. Min.	5.32	6 [†]	mg/l	1
Chlorine, Total Residual	July 2013	Avg. Monthly	0.07	0.009	mg/l	31*
Chlorine, Total Residual	July 2013	Max. Daily	0.07	0.018	mg/l	1
pH	June 2013	Inst. Min.	5.30	6 [†]	S.U.	1
Dissolved Oxygen	June 2013	Inst. Min.	5.82	6 [†]	mg/l	1
Chlorine, Total Residual	June 2013	Avg. Monthly	0.04	0.009	mg/l	30*
Chlorine, Total Residual	June 2013	Max. Daily	0.04	0.018	mg/l	1
Biochemical Oxygen Demand	April 2013	Avg. Monthly	6.5	5	mg/l	30*
Biochemical Oxygen Demand	April 2013	Max. Daily	11.0	10	mg/l	1
pH	April 2013	Inst. Min.	5.50	6 [†]	S.U.	1
Nitrogen, Ammonia Total	April 2013	Avg. Monthly	3.20	3	mg/l	30*
pH	March 2013	Inst. Min.	5.10	6 [†]	S.U.	1

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Nitrogen, Ammonia Total	March 2013	Avg. Monthly	3.25	3	mg/l	31*
Chlorine, Total Residual	March 2013	Avg. Monthly	0.03	0.009	mg/l	31*
Chlorine, Total Residual	March 2013	Max. Daily	0.03	0.018	mg/l	1
Nitrogen, Ammonia Total	February 2013	Avg. Monthly	11.70	3	mg/l	28*
Nitrogen, Ammonia Total	February 2013	Max. Daily	11.70	6	mg/l	1
Chlorine, Total Residual	February 2013	Avg. Monthly	0.04	0.009	mg/l	28*
Chlorine, Total Residual	February 2013	Max. Daily	0.04	0.018	mg/l	1
Biochemical Oxygen Demand	December 2012	Avg. Monthly	7.8	5	mg/l	31*
Nitrogen, Ammonia Total	December 2012	Avg. Monthly	12.10	3	mg/l	31*
Nitrogen, Ammonia Total	December 2012	Max. Daily	12.10	6	mg/l	1
Chlorine, Total Residual	December 2012	Avg. Monthly	0.05	0.009	mg/l	31*
Chlorine, Total Residual	December 2012	Max. Daily	0.05	0.018	mg/l	1
pH	November 2012	Inst. Min.	5.76	6 [†]	S.U.	1
Chlorine, Total Residual	November 2012	Avg. Monthly	0.059	0.009	mg/l	30*
Chlorine, Total Residual	November 2012	Max. Daily	0.059	0.018	mg/l	1
pH	October 2012	Inst. Min.	5.69	6 [†]	S.U.	1
Nitrogen, Ammonia Total	October 2012	Avg. Monthly	6.20	3	mg/l	31*
Nitrogen, Ammonia Total	October 2012	Max. Daily	6.20	6	mg/l	1
pH	August 2012	Inst. Min.	5.70	6 [†]	S.U.	1
Chlorine, Total Residual	July 2012	Avg. Monthly	0.24	0.009	mg/l	31*
Chlorine, Total Residual	July 2012	Max. Daily	0.48	0.018	mg/l	1
Dissolved Oxygen	June 2012	Inst. Min.	5.93	6 [†]	mg/l	1
Biochemical Oxygen Demand	June 2012	Avg. Monthly	N/T [‡]	0.31	lbs/day	30*
Biochemical Oxygen Demand	June 2012	Max. Daily	N/T [‡]	0.62	lbs/day	1
Biochemical Oxygen Demand	June 2012	Avg. Monthly	N/T [‡]	5	mg/l	30*
Biochemical Oxygen Demand	June 2012	Max. Daily	N/T [‡]	10	mg/l	1
Total Suspended Solids	June 2012	Avg. Monthly	N/T [‡]	1.88	lbs/day	30*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Total Suspended Solids	June 2012	Max. Daily	N/T [†]	3.76	lbs/day	1
Total Suspended Solids	June 2012	Avg. Monthly	N/T [†]	30	mg/l	30*
Total Suspended Solids	June 2012	Max. Daily	N/T [†]	60	mg/l	1
pH	June 2012	Inst. Min.	N/T [†]	6 [†]	S.U.	1
pH	June 2012	Inst. Max	N/T [†]	9	S.U.	1
Nitrogen, Ammonia Total	June 2012	Avg. Monthly	N/T [†]	0.19	lbs/day	30*
Nitrogen, Ammonia Total	June 2012	Max. Daily	N/T [†]	0.38	lbs/day	1
Nitrogen, Ammonia Total	June 2012	Avg. Monthly	N/T [†]	3	mg/l	30*
Nitrogen, Ammonia Total	June 2012	Max. Daily	N/T [†]	6	mg/l	1
Chlorine, Total Residual	June 2012	Avg. Monthly	N/T [†]	0.009	mg/l	30*
Chlorine, Total Residual	June 2012	Max. Daily	N/T [†]	0.018	mg/l	1
Dissolved Oxygen	May 2012	Inst. Min.	5.21	6 [†]	mg/l	1
Nitrogen, Ammonia Total	May 2012	Avg. Monthly	4.75	3	mg/l	31*
Chlorine, Total Residual	May 2012	Avg. Monthly	0.09	0.009	mg/l	31*
Chlorine, Total Residual	May 2012	Max. Daily	0.09	0.018	mg/l	1
Biochemical Oxygen Demand	April 2012	Avg. Monthly	7.0	5	mg/l	30*
Fecal Coliform	April 2012	Monthly Mean	>790	200	per 100ml	30*
Fecal Coliform	April 2012	Max. Daily	>1200	400	per 100ml	1
Dissolved Oxygen	April 2012	Inst. Min.	5.26	6 [†]	mg/l	1
Nitrogen, Ammonia Total	April 2012	Avg. Monthly	6.87	3	mg/l	30*
Nitrogen, Ammonia Total	April 2012	Max. Daily	6.87	6	mg/l	1
Chlorine, Total Residual	April 2012	Avg. Monthly	0.2	0.009	mg/l	30*
Chlorine, Total Residual	April 2012	Max. Daily	0.4	0.018	mg/l	1
Biochemical Oxygen Demand	March 2012	Avg. Monthly	103	5	mg/l	31*
Biochemical Oxygen Demand	March 2012	Max. Daily	188	10	mg/l	1
Dissolved Oxygen	March 2012	Inst. Min.	0.51	6 [†]	mg/l	1
Nitrogen, Ammonia Total	March 2012	Avg. Monthly	15.6	3	mg/l	31*
Nitrogen, Ammonia Total	March 2012	Max. Daily	21.4	6	mg/l	1

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Chlorine, Total Residual	March 2012	Avg. Monthly	0.06	0.009	mg/l	31*
Chlorine, Total Residual	March 2012	Max. Daily	0.08	0.018	mg/l	1
Biochemical Oxygen Demand	February 2012	Avg. Monthly	9.8	5	mg/l	29*
Nitrogen, Ammonia Total	February 2012	Avg. Monthly	0.2486	0.19	lbs/day	29*
Nitrogen, Ammonia Total	February 2012	Avg. Monthly	20.7	3	mg/l	29*
Nitrogen, Ammonia Total	February 2012	Max. Daily	20.7	6	mg/l	1
Chlorine, Total Residual	February 2012	Avg. Monthly	0.01	0.009	mg/l	29*
Fecal Coliform	January 2012	Monthly Mean	2500	200	per 100ml	31*
Fecal Coliform	January 2012	Max. Daily	5000	400	per 100ml	1
pH	January 2012	Inst. Min.	5.71	6†	S.U.	1
Nitrogen, Ammonia Total	January 2012	Avg. Monthly	8.85	3	mg/l	31*
Nitrogen, Ammonia Total	January 2012	Max. Daily	8.85	6	mg/l	1
Fecal Coliform	December 2011	Monthly Mean	210	200	per 100ml	31*
Nitrogen, Ammonia Total	December 2011	Avg. Monthly	7.21	3	mg/l	31*
Nitrogen, Ammonia Total	December 2011	Max. Daily	7.21	6	mg/l	1
Biochemical Oxygen Demand	November 2011	Avg. Monthly	11.9	5	mg/l	30*
Biochemical Oxygen Demand	November 2011	Max. Daily	18.0	10	mg/l	1
Fecal Coliform	November 2011	Monthly Mean	3005	200	per 100ml	30*
Fecal Coliform	November 2011	Max. Daily	>6000	400	per 100ml	1
Nitrogen, Ammonia Total	November 2011	Avg. Monthly	15.4	3	mg/l	30*
Nitrogen, Ammonia Total	November 2011	Max. Daily	29	6	mg/l	1
Chlorine, Total Residual	November 2011	Avg. Monthly	0.10	0.009	mg/l	30*
Biochemical Oxygen Demand	October 2011	Avg. Monthly	8.0	5	mg/l	31*
Dissolved Oxygen	October 2011	Inst. Min.	4.11	6†	mg/l	1
Biochemical Oxygen Demand	September 2011	Avg. Monthly	6.4	5	mg/l	30*
Dissolved Oxygen	September 2011	Inst. Min.	4.15	6†	mg/l	1
Nitrogen, Ammonia Total	September 2011	Avg. Monthly	10.3	3	mg/l	30*
Nitrogen, Ammonia Total	September 2011	Max. Daily	10.3	6	mg/l	1

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Chlorine, Total Residual	September 2011	Avg. Monthly	0.02	0.009	mg/l	30*
Chlorine, Total Residual	September 2011	Max. Daily	0.02	0.018	mg/l	1
Biochemical Oxygen Demand	August 2011	Avg. Monthly	12.6	5	mg/l	31*
Biochemical Oxygen Demand	August 2011	Max. Daily	12.2	10	mg/l	1
Dissolved Oxygen	August 2011	Inst. Min.	4.27	6 [†]	mg/l	1
Nitrogen, Ammonia Total	August 2011	Avg. Monthly	4.81	3	mg/l	31*
Chlorine, Total Residual	August 2011	Avg. Monthly	0.14	0.009	mg/l	31*
Chlorine, Total Residual	August 2011	Max. Daily	0.29	0.018	mg/l	1
Nitrogen, Ammonia Total	July 2011	Avg. Monthly	4.33	3	mg/l	31*
Chlorine, Total Residual	July 2011	Avg. Monthly	0.38	0.009	mg/l	31*
Chlorine, Total Residual	July 2011	Max. Daily	0.38	0.018	mg/l	1
Fecal Coliform	June 2011	Monthly Mean	5600	200	per 100ml	30*
Fecal Coliform	June 2011	Max. Daily	5600	400	per 100ml	1
Dissolved Oxygen	June 2011	Inst. Min.	5.02	6 [†]	mg/l	1
Nitrogen, Ammonia Total	June 2011	Avg. Monthly	0.4221	0.19	lbs/day	30*
Nitrogen, Ammonia Total	June 2011	Max. Daily	0.4221	0.38	lbs/day	1
Nitrogen, Ammonia Total	June 2011	Avg. Monthly	11	3	mg/l	30*
Nitrogen, Ammonia Total	June 2011	Max. Daily	11	6	mg/l	1
Chlorine, Total Residual	June 2011	Avg. Monthly	0.01	0.009	mg/l	30*
Dissolved Oxygen	May 2011	Inst. Min.	4.88	6 [†]	mg/l	1
Nitrogen, Ammonia Total	May 2011	Avg. Monthly	4.45	3	mg/l	31*
Chlorine, Total Residual	May 2011	Avg. Monthly	0.02	0.009	mg/l	31*
Chlorine, Total Residual	May 2011	Max. Daily	0.02	0.018	mg/l	1
Flow, In Conduit or Through Plant	March 2011	Max. Daily	0.0094	0.0075	mgd	1
Biochemical Oxygen Demand	March 2011	Avg. Monthly	1.3329	0.31	lbs/day	31*
Biochemical Oxygen Demand	March 2011	Max. Daily	1.3329	0.62	lbs/day	1
Biochemical Oxygen Demand	March 2011	Avg. Monthly	17	5	mg/l	31*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Biochemical Oxygen Demand	March 2011	Max. Daily	17	10	mg/l	1
Nitrogen, Ammonia Total	March 2011	Avg. Monthly	1.0036	0.19	lbs/day	31*
Nitrogen, Ammonia Total	March 2011	Max. Daily	1.0036	0.38	lbs/day	1
Nitrogen, Ammonia Total	March 2011	Avg. Monthly	12.8	3	mg/l	31*
Nitrogen, Ammonia Total	March 2011	Max. Daily	12.8	6	mg/l	1
Chlorine, Total Residual	March 2011	Avg. Monthly	0.08	0.009	mg/l	31*
Chlorine, Total Residual	March 2011	Max. Daily	0.08	0.018	mg/l	1
Biochemical Oxygen Demand	February 2011	Avg. Monthly	11.0	5	mg/l	28*
Biochemical Oxygen Demand	February 2011	Max. Daily	11.0	10	mg/l	1
Fecal Coliform	February 2011	Monthly Mean	4600	200	per 100ml	28*
Fecal Coliform	February 2011	Max. Daily	4600	400	per 100ml	1
Nitrogen, Ammonia Total	February 2011	Avg. Monthly	4.91	3	mg/l	28*
Chlorine, Total Residual	February 2011	Avg. Monthly	0.21	0.009	mg/l	28*
Chlorine, Total Residual	February 2011	Max. Daily	0.21	0.018	mg/l	1
Biochemical Oxygen Demand	January 2011	Avg. Monthly	22.0	5	mg/l	31*
Biochemical Oxygen Demand	January 2011	Max. Daily	22.0	10	mg/l	1
Nitrogen, Ammonia Total	January 2011	Avg. Monthly	13.5	3	mg/l	31*
Nitrogen, Ammonia Total	January 2011	Max. Daily	13.5	6	mg/l	1
Biochemical Oxygen Demand	December 2010	Avg. Monthly	7	5	mg/l	31*
Dissolved Oxygen	December 2010	Inst. Min.	5.51	6†	mg/l	1
Nitrogen, Ammonia Total	December 2010	Avg. Monthly	0.2684	0.19	lbs/day	31*
Nitrogen, Ammonia Total	December 2010	Avg. Monthly	18.6	3	mg/l	31*
Nitrogen, Ammonia Total	December 2010	Max. Daily	18.6	6	mg/l	1
Biochemical Oxygen Demand	November 2010	Avg. Monthly	16	5	mg/l	30*
Biochemical Oxygen Demand	November 2010	Max. Daily	16	10	mg/l	1
Nitrogen, Ammonia Total	November 2010	Avg. Monthly	3.96	3	mg/l	30*
Chlorine, Total Residual	November 2010	Avg. Monthly	0.08	0.009	mg/l	30*
Chlorine, Total Residual	November 2010	Max. Daily	0.08	0.018	mg/l	1

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Biochemical Oxygen Demand	October 2010	Avg. Monthly	10.0	5	mg/l	31*
Chlorine, Total Residual	October 2010	Avg. Monthly	0.08	0.009	mg/l	31*
Chlorine, Total Residual	October 2010	Max. Daily	0.08	0.018	mg/l	1
Biochemical Oxygen Demand	September 2010	Avg. Monthly	18.5	5	mg/l	30*
Biochemical Oxygen Demand	September 2010	Max. Daily	23.0	10	mg/l	1
Nitrogen, Ammonia Total	September 2010	Avg. Monthly	0.2586	0.19	lbs/day	30*
Nitrogen, Ammonia Total	September 2010	Max. Daily	0.4221	0.38	lbs/day	1
Nitrogen, Ammonia Total	September 2010	Avg. Monthly	15.5	3	mg/l	30*
Nitrogen, Ammonia Total	September 2010	Max. Daily	25.3	6	mg/l	1
Chlorine, Total Residual	September 2010	Avg. Monthly	0.02	0.009	mg/l	30*
Chlorine, Total Residual	September 2010	Max. Daily	0.02	0.018	mg/l	1
Biochemical Oxygen Demand	August 2010	Avg. Monthly	8.0	5	mg/l	31*
Chlorine, Total Residual	August 2010	Avg. Monthly	0.03	0.009	mg/l	31*
Chlorine, Total Residual	August 2010	Max. Daily	0.03	0.018	mg/l	1
Biochemical Oxygen Demand	July 2010	Avg. Monthly	0.60	0.31	lbs/day	31*
Biochemical Oxygen Demand	July 2010	Avg. Monthly	18.0	5	mg/l	31*
Biochemical Oxygen Demand	July 2010	Max. Daily	18.0	10	mg/l	1
Dissolved Oxygen	July 2010	Inst. Min.	3.97	6 [†]	mg/l	1
Chlorine, Total Residual	July 2010	Avg. Monthly	0.03	0.009	mg/l	31*
Chlorine, Total Residual	July 2010	Max. Daily	0.03	0.018	mg/l	1
Total Suspended Solids	June 2010	Avg. Monthly	31	30	mg/l	30*
Dissolved Oxygen	June 2010	Inst. Min.	5.33	6 [†]	mg/l	1
Nitrogen, Ammonia Total	June 2010	Avg. Monthly	4.01	3	mg/l	30*
Chlorine, Total Residual	June 2010	Avg. Monthly	0.07	0.009	mg/l	30*
Chlorine, Total Residual	June 2010	Max. Daily	0.07	0.018	mg/l	1
Biochemical Oxygen Demand	May 2010	Avg. Monthly	17.0	5	mg/l	31*
Biochemical Oxygen Demand	May 2010	Max. Daily	17.0	10	mg/l	1

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Dissolved Oxygen	May 2010	Inst. Min.	4.16	6 [†]	mg/l	1
Chlorine, Total Residual	May 2010	Avg. Monthly	0.03	0.009	mg/l	31*
Chlorine, Total Residual	May 2010	Max. Daily	0.03	0.018	mg/l	1
Biochemical Oxygen Demand	April 2010	Avg. Monthly	0.38	0.31	lbs/day	30*
Biochemical Oxygen Demand	April 2010	Avg. Monthly	25	5	mg/l	30*
Biochemical Oxygen Demand	April 2010	Max. Daily	25	10	mg/l	1
Nitrogen, Ammonia Total	April 2010	Avg. Monthly	5.65	3	mg/l	30*
Chlorine, Total Residual	April 2010	Avg. Monthly	0.09	0.009	mg/l	30*
Chlorine, Total Residual	April 2010	Max. Daily	0.09	0.018	mg/l	1
Nitrogen, Ammonia Total	March 2010	Avg. Monthly	3.38	3	mg/l	31*
Flow, In Conduit or Through Plant	February 2010	Max. Daily	0.0079	0.0075	mgd	1
Nitrogen, Ammonia Total	February 2010	Avg. Monthly	0.41	0.19	lbs/day	28*
Nitrogen, Ammonia Total	February 2010	Max. Daily	0.41	0.38	lbs/day	1
Nitrogen, Ammonia Total	February 2010	Avg. Monthly	6.24	3	mg/l	28*
Nitrogen, Ammonia Total	February 2010	Max. Daily	6.24	6	mg/l	1
Chlorine, Total Residual	February 2010	Avg. Monthly	0.05	0.009	mg/l	28*
Chlorine, Total Residual	February 2010	Max. Daily	0.05	0.018	mg/l	1
Fecal Coliform	January 2010	Monthly Mean	636	200	per 100ml	31*
Fecal Coliform	January 2010	Max. Daily	636	400	per 100ml	1
Nitrogen, Ammonia Total	January 2010	Avg. Monthly	9.05	3	mg/l	31*
Nitrogen, Ammonia Total	January 2010	Max. Daily	9.05	6	mg/l	1
Chlorine, Total Residual	January 2010	Avg. Monthly	0.01	0.009	mg/l	31*
Biochemical Oxygen Demand	December 2009	Avg. Monthly	6.0	5	mg/l	31*
Fecal Coliform	December 2009	Monthly Mean	1460	200	per 100ml	31*
Fecal Coliform	December 2009	Max. Daily	1460	400	per 100ml	1
pH	December 2009	Inst. Min.	5.93	6 [†]	S.U.	1
Nitrogen, Ammonia Total	December 2009	Avg. Monthly	3.77	3	mg/l	31*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Biochemical Oxygen Demand	November 2009	Avg. Monthly	18	5	mg/l	30*
Biochemical Oxygen Demand	November 2009	Max. Daily	18	10	mg/l	1
Dissolved Oxygen	November 2009	Inst. Min.	4.67	6 [†]	mg/l	1
Chlorine, Total Residual	November 2009	Avg. Monthly	0.02	0.009	mg/l	30*
Chlorine, Total Residual	November 2009	Max. Daily	0.02	0.018	mg/l	1
Biochemical Oxygen Demand	October 2009	Avg. Monthly	6	5	mg/l	31*
Chlorine, Total Residual	September 2009	Avg. Monthly	0.04	0.009	mg/l	30*
Chlorine, Total Residual	September 2009	Max. Daily	0.04	0.018	mg/l	1
Chlorine, Total Residual	August 2009	Avg. Monthly	0.04	0.009	mg/l	31*
Chlorine, Total Residual	August 2009	Max. Daily	0.04	0.018	mg/l	1
Biochemical Oxygen Demand	July 2009	Avg. Monthly	0.38	0.31	lbs/day	31*
Biochemical Oxygen Demand	July 2009	Avg. Monthly	6.0	5	mg/l	31*
Dissolved Oxygen	July 2009	Inst. Min.	4.52	6 [†]	mg/l	1
Chlorine, Total Residual	July 2009	Avg. Monthly	0.32	0.009	mg/l	31*
Chlorine, Total Residual	July 2009	Max. Daily	0.32	0.018	mg/l	1
Chlorine, Total Residual	June 2009	Avg. Monthly	50.0	0.009	mg/l	30*
Chlorine, Total Residual	June 2009	Max. Daily	50.0	0.018	mg/l	1
Dissolved Oxygen	May 2009	Inst. Min.	N/T [‡]	6 [†]	mg/l	1
Chlorine, Total Residual	May 2009	Avg. Monthly	0.07	0.009	mg/l	31*
Chlorine, Total Residual	May 2009	Max. Daily	0.07	0.018	mg/l	1
Biochemical Oxygen Demand	April 2009	Avg. Monthly	6.0	5	mg/l	30*
Dissolved Oxygen	April 2009	Inst. Min.	N/T [‡]	6 [†]	mg/l	1
Biochemical Oxygen Demand	March 2009	Avg. Monthly	7.0	5	mg/l	31*
Fecal Coliform	March 2009	Monthly Mean	400	200	per 100ml	31*
Dissolved Oxygen	March 2009	Inst. Min.	5.3	6 [†]	mg/l	1
Nitrogen, Ammonia Total	March 2009	Avg. Monthly	3.9	3	mg/l	31*
Chlorine, Total Residual	March 2009	Avg. Monthly	90.00	9	ug/l	31*

Outlet 009						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Chlorine, Total Residual	March 2009	Max. Daily	90.00	18	ug/l	1
Total Violations at Outlet 009						4,813
Outlet 005						
Parameter	Month	Type	Reported	Limit	Unit	Violations
Water Temperature	September 2014	Avg. Monthly	75.4	75.2	°F	30*
pH	June 2013	Inst. Min.	5.02	6†	S.U.	1
pH	September 2010	Inst. Min.	5.15	6†	S.U.	1
pH	June 2009	Inst. Min.	5.72	6†	S.U.	1
Total Violations at Outlet 005						33
<p>* See <u>Chesapeake Bay Foundation, Inc. v. Gwaltney of Smithfield, Ltd.</u>, 791 F.3d 304, 313-315 (4th Cir. 1986) (violation of an average monthly effluent limitation is appropriately considered a violation of the limit for each day of that month), <u>vac'd on other grounds</u>, 484 U.S. 49 (1987).</p> <p>† Minimum Limitation</p> <p>‡ Quantity or Concentration of Pollutant Not Tested or Reported</p>			<p>Total Permit Violations 4,846</p>			